



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



ORELAP WA200008
Idaho WA00097
Page 1 of 2

ORGANICS IN DRINKING WATER

Client Name: Hillsboro, City of
150 E. Main Street
Hillsboro, OR 97123

Reference Number: 19-14321

Project: Semi-Annual Joint Water Comis

System Name: JOINT WATER COMMISSION
System ID Number: 4100379
DWP Source Number: EP-A
Multiple Sources:
Sample Type: A - After treatment
Sample Purpose: C - Compliance
Sample Composition: Single Source
Sample Location: JWTP FW Hose - Site ID #1
County: Washington

Field ID: Site ID #1
Lab Number: 19_28990
Date Collected: 4/24/19 08:45
Sampled By: Robb Davis
Sampler Phone:
Report Date: 6/14/19
Approved By: hjb,hy,pdm

Authorized By:

Thanh B Phan
Lab Manager, Portland

| EPA# | COMPOUNDS | RESULTS | UNITS | LRL | MCL | METHOD | Analyst | Lab | Analyzed | COMMENT |
|------------------------------------|-----------------------------|---------|-------|---------|--------|--------|---------|--------|----------|--------------------|
| EPA Unregulated | | | | | | | | | | |
| 2043 | ALDICARB SULFOXIDE | ND | mg/L | | 0.004 | 531.2 | MER | 200001 | 05/17/19 | Analyzed by Anatek |
| 2044 | ALDICARB SULFONE | ND | mg/L | | 0.002 | 531.2 | MER | 200001 | 05/17/19 | Analyzed by Anatek |
| 2022 | METHOMYL | ND | mg/L | | | 531.2 | MER | 200001 | 05/17/19 | Analyzed by Anatek |
| 2047 | ALDICARB | ND | mg/L | | 0.003 | 531.2 | MER | 200001 | 05/17/19 | Analyzed by Anatek |
| 2021 | CARBARYL | ND | mg/L | | | 531.2 | MER | 200001 | 05/17/19 | Analyzed by Anatek |
| Synthetic Organic Chemicals | | | | | | | | | | |
| 2105 | 2,4 - D | ND | mg/L | 0.0001 | 0.070 | 515.4 | ELW | 4072 | 04/30/19 | |
| 2110 | 2,4,5 - TP (SILVEX) | ND | mg/L | 0.0001 | 0.050 | 515.4 | ELW | 4072 | 04/30/19 | |
| 2035 | DI(2-ETHYLHEXYL)-ADIPATE | ND | mg/L | 0.00005 | 0.400 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2051 | ALACHLOR | ND | mg/L | 0.00005 | 0.002 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2050 | ATRAZINE | ND | mg/L | 0.00005 | 0.003 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2306 | BENZO(A)PYRENE | ND | mg/L | 0.00005 | 0.0002 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2010 | LINDANE (BHC - GAMMA) | ND | mg/L | 0.00005 | 0.0002 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2046 | CARBOFURAN | ND | mg/L | 0.001 | 0.040 | 531.2 | MER | 200001 | 05/17/19 | Analyzed by Anatek |
| 2959 | CHLORDANE | ND | mg/L | 0.0001 | 0.002 | 508.1 | KRH | 4072 | 04/29/19 | |
| 2031 | DALAPON | ND | mg/L | 0.0005 | 0.200 | 515.4 | ELW | 4072 | 05/16/19 | |
| 2931 | 1,2-DIBROMO-3-CHLOROPROPANE | ND | mg/L | 0.00002 | 0.0002 | 504.1 | MA | 4072 | 05/02/19 | |
| 2041 | DINOSEB | ND | mg/L | 0.0001 | 0.007 | 515.4 | ELW | 4072 | 04/30/19 | |
| 2032 | DIQUAT | ND | mg/L | 0.002 | 0.020 | 549.2 | GSL | 4072 | 05/14/19 | |
| 2033 | ENDOTHALL | ND | mg/L | 0.005 | 0.100 | 548.1 | MA | 4072 | 05/01/19 | |
| 2005 | ENDRIN | ND | mg/L | 0.00005 | 0.002 | 525.2 | KRH | 4072 | 05/03/19 | |

NOTES:
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; a blank MCL value indicates a level is not currently established.
ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting Limit (LRL).

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

If you have any questions concerning this report contact Thanh B Phan at the above phone number.

FORM: SOC_OR

ORGANICS IN DRINKING WATER

| EPA# | COMPOUNDS | RESULTS | UNITS | LRL | MCL | METHOD | Analyst | Lab | Analyzed | COMMENT |
|------|----------------------------|---------|-------|---------|---------|--------|---------|--------|----------|--------------------|
| 2946 | 1,2 - DIBROMOETHANE (EDB) | ND | mg/L | 0.00002 | 0.0000E | 504.1 | MA | 4072 | 05/02/19 | |
| 2034 | GLYPHOSATE | ND | mg/L | 0.005 | 0.700 | 547 | ELW | 4072 | 05/01/19 | |
| 2067 | HEPTACHLOR EPOXIDE "B" | ND | mg/L | 0.00005 | 0.0002 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2065 | HEPTACHLOR | ND | mg/L | 0.00005 | 0.0004 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2274 | HEXACHLOROBENZENE | ND | mg/L | 0.00005 | 0.001 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2042 | HEXACHLOROCYCLO-PENTADIENE | ND | mg/L | 0.00005 | 0.050 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2015 | METHOXYCHLOR | ND | mg/L | 0.00005 | 0.040 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2326 | PENTACHLOROPHENOL | ND | mg/L | 0.00004 | 0.001 | 515.4 | ELW | 4072 | 04/30/19 | |
| 2039 | DI(2-ETHYLHEXYL)-PHTHALATE | ND | mg/L | 0.0001 | 0.006 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2040 | PICLORAM | ND | mg/L | 0.0001 | 0.500 | 515.4 | ELW | 4072 | 04/30/19 | |
| 2037 | SIMAZINE | ND | mg/L | 0.00005 | 0.004 | 525.2 | KRH | 4072 | 05/03/19 | |
| 2020 | TOXAPHENE | ND | mg/L | 0.001 | 0.003 | 508.1 | KRH | 4072 | 04/29/19 | |
| 2036 | OXAMYL (VYDATE) | ND | mg/L | 0.001 | 0.200 | 531.2 | MER | 200001 | 05/17/19 | Analyzed by Anatek |
| 2383 | PCBS (Total Aroclors) | ND | mg/L | 0.0002 | 0.0005 | 508.1 | KRH | 4072 | 04/29/19 | |

NOTES:

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; a blank MCL value indicates a level is not currently established.
 ND (Not Detected); indicates that the parameter was not detected above the Lower Reporting Limit (LRL).

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

If you have any questions concerning this report contact Thanh B Phan at the above phone number.