



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hillsboro, City of
150 E. Main Street
Hillsboro, OR 97123

Reference Number: 16-02265
Project: Semi-Annual Joint Water Commis

System Name: JOINT WATER COMMISSION
System ID Number: 4100379
Source Number: EP-A
Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: JWTP FW Hose - Site ID #1
County: Washington

Sample Number: Site ID#1
Lab Number: 16_05265
Collect Date: 2/2/16 08:18
Date Received: 2/2/16
Report Date: 3/10/16
Sampled By: Brian Monnin/Rachel Smith
Sampler Phone:
Approved by: ajs,bj,cpo,mvp,tdp
Authorized by:

Thanh B Phan
Lab Manager, Portland

EPA#	ANALYTES	RESULTS	UNITS	LRL	MCL	Analyst	Lab Code*	METHOD	Analyzed	COMMENT
1074	ANTIMONY	ND	mg/L	0.001	0.006	mvp	4072 a	200.8	02/05/16	
1005	ARSENIC	ND	mg/L	0.001	0.010	mvp	4072 a	200.8	02/05/16	
1075	BERYLLIUM	ND	mg/L	0.001	0.004	mvp	4072 a	200.8	02/05/16	
1010	BARIUM	0.005	mg/L	0.001	2	mvp	4072 a	200.8	02/05/16	
1015	CADMIUM	ND	mg/L	0.001	0.005	mvp	4072 a	200.8	02/05/16	
1020	CHROMIUM	ND	mg/L	0.010	0.1	mvp	4072 a	200.8	02/05/16	
1064	ELECTRICAL CONDUCTIVITY	91.21	uS/cm	10	700	tdp	OR100063 c	SM2510 B	02/05/16	
1030	LEAD	ND	mg/L	0.001	0.015	mvp	4072 a	200.8	02/05/16	
1036	NICKEL	ND	mg/L	0.005	0.1	mvp	4072 a	200.8	02/05/16	
1045	SELENIUM	ND	mg/L	0.005	0.05	mvp	4072 a	200.8	02/05/16	
1085	THALLIUM	ND	mg/L	0.001	0.002	mvp	4072 a	200.8	02/05/16	
1035	MERCURY	ND	mg/L	0.0002	0.002	mmh	4072 a	245.1	02/05/16	
1024	CYANIDE, FREE	ND	mg/L	0.010	0.2	anp	4072 a	OIA-1677-DW	02/10/16	
1052	SODIUM	8.9	mg/L	0.5	20	bj	4072 a	200.7	02/09/16	
1025	FLUORIDE	ND	mg/L	0.20	4	mmh	4072 a	300.0	02/06/16	
1905	COLOR	ND	Color Units	5	15	ajs	OR100063 c	SM2120 B	02/02/16 16:26	pH:7.02
1040	NITRATE-N	0.52	mg/L	0.005	10	cpo	OR100063 c	SM4500-NO3 F	02/02/16	
1041	NITRITE-N	ND	mg/L	0.005	1.0	cpo	OR100063 c	SM4500-NO3 F	02/02/16	
1038	TOTAL NITRATE/NITRITE	0.52	mg/L	0.010	10	cpo	OR100063 c	SM4500-NO3 F	02/02/16	
0100	TURBIDITY	0.06	NTU	0.02	1	cpo	OR100063 c	180.1	02/03/16 15:04	

NOTES:

ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting limit (LRL).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

* Lab Code - lists the laboratory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

If you have any questions concerning this report contact us at the above phone number.