



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946

ORELAP WA200008  
Idaho WA00097

## VOLATILE ORGANIC COMPOUNDS (VOC) REPORT

Client Name: Hillsboro, City of  
150 E. Main Street  
Hillsboro, OR 97123

Reference Number: 14-14770  
Project: Semi Annual - JWTP FW

System Name: JOINT WATER COMMISSION  
System ID Number: 4100397  
DWP Source Number:  
Multiple Sources:  
Sample Type: A - After treatment  
Sample Purpose: C - Compliance  
Sample Location: JWTP FW Hose  
County: Washington  
Sampled By: Brian Monnin  
Sampler Phone:

Field ID: Site #1  
Lab Number: 14\_34289  
Date Collected: 8/6/14 11:20  
Date Extracted: 524\_140808  
Date Analyzed: 08/12/14  
Report Date: 10/1/14  
Analyst: HY  
Approved By: pdm

Authorized By:

Lawrence Henderson, PhD  
Director of Laboratories, Vice President

EPA#	COMPOUNDS	RESULTS	UNITS	LRL	MCL	Method	Lab	COMMENT
<b>EPA/State Regulated</b>								
2977	1,1 - DICHLOROETHYLENE	ND	mg/L	0.0005	0.007	524.2	WA200008	
2981	1,1,1 - TRICHLOROETHANE	ND	mg/L	0.0005	0.200	524.2	WA200008	
2985	1,1,2 - TRICHLOROETHANE	ND	mg/L	0.0005	0.005	524.2	WA200008	
2980	1,2 - DICHLOROETHANE	ND	mg/L	0.0005	0.005	524.2	WA200008	
2983	1,2 - DICHLOROPROPANE	ND	mg/L	0.0005	0.005	524.2	WA200008	
2378	1,2,4 - TRICHLOROBENZENE	ND	mg/L	0.0005	0.070	524.2	WA200008	
2990	BENZENE	ND	mg/L	0.0005	0.005	524.2	WA200008	
2982	CARBON TETRACHLORIDE	ND	mg/L	0.0005	0.005	524.2	WA200008	
2989	CHLOROBENZENE	ND	mg/L	0.0005	0.100	524.2	WA200008	
2380	CIS - 1,2 - DICHLOROETHYLENE	ND	mg/L	0.0005	0.070	524.2	WA200008	
2992	ETHYLBENZENE	ND	mg/L	0.0005	0.700	524.2	WA200008	
2964	METHYLENE CHLORIDE	ND	mg/L	0.0005	0.005	524.2	WA200008	
2968	O - DICHLOROBENZENE	ND	mg/L	0.0005	0.600	524.2	WA200008	
2969	P - DICHLOROBENZENE	ND	mg/L	0.0005	0.075	524.2	WA200008	
2996	STYRENE	ND	mg/L	0.0005	0.100	524.2	WA200008	
2979	T - 1,2 - DICHLOROETHYLENE	ND	mg/L	0.0005	0.100	524.2	WA200008	
2987	TETRACHLOROETHYLENE	ND	mg/L	0.0005	0.005	524.2	WA200008	Field Dup: 0.0002 mg/L, TB: ND
2991	TOLUENE	ND	mg/L	0.0005	1.0	524.2	WA200008	
2955	TOTAL XYLENES	ND	mg/L	0.0005	10.0	524.2	WA200008	
2984	TRICHLOROETHYLENE	ND	mg/L	0.0005	0.005	524.2	WA200008	
2976	VINYL CHLORIDE	ND	mg/L	0.0005	0.002	524.2	WA200008	

**NOTES:**  
If a compound is detected > or = to the Lower Reporting Level, LRL, specified increased monitoring frequencies may occur per PHD.  
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA. Blank MCL value indicates a level is not currently established.  
ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting Limit (LRL).

If you have any questions concerning this report contact our office at the above phone number.