



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hillsboro, City of  
150 E. Main Street  
Hillsboro, OR 97123

Reference Number: 20-07437  
Project: ASR Monitoring - Rush IOCs

System Name:  
System ID Number:  
Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
Sample Location: JWC-FW  
County:

Sample Number: 1  
Lab Number: 20\_14540  
Collect Date: 3/2/20 09:03  
Date Received: 3/2/20  
Report Date: 3/10/20  
Sampled By: JA/IR  
Sampler Phone:  
Approved by: ajw,bj,bsp  
Authorized by:

Thanh B Phan  
Lab Manager, Portland

EPA#	ANALYTES	RESULTS	UNITS	LRL	MCL	Analyst	Lab Code*	METHOD	Analyzed	COMMENT
	<b>EPA Regulated</b>									
1005	ARSENIC	ND	mg/L	0.001	0.010	ajw	4072 a	200.8	03/05/20	
1010	BARIUM	0.0042	mg/L	0.001	2	ajw	4072 a	200.8	03/05/20	
1015	CADMIUM	ND	mg/L	0.001	0.005	ajw	4072 a	200.8	03/05/20	
1020	CHROMIUM	ND	mg/L	0.001	0.1	ajw	4072 a	200.8	03/05/20	
1035	MERCURY	ND	mg/L	0.0002	0.002	ajw	4072 a	245.1	03/09/20	
1045	SELENIUM	ND	mg/L	0.002	0.05	ajw	4072 a	200.8	03/05/20	
1075	BERYLLIUM	ND	mg/L	0.0003	0.004	ajw	4072 a	200.8	03/05/20	
1036	NICKEL	ND	mg/L	0.001		ajw	4072 a	200.8	03/05/20	
1074	ANTIMONY	ND	mg/L	0.001	0.006	ajw	4072 a	200.8	03/05/20	
1085	THALLIUM	ND	mg/L	0.0001	0.002	ajw	4072 a	200.8	03/05/20	
1024	CYANIDE, AVAILABLE	ND	mg/L	0.01	0.2	bsp	4072 a	OIA-1677-DW	03/03/20	
1025	FLUORIDE	ND	mg/L	0.10	4	ajw	4072 a	300.0	03/04/20	
	<b>EPA Regulated (Secondary)</b>									
1028	IRON	ND	mg/L	0.050	0.3	bj	4072 a	200.7	03/09/20	
1032	MANGANESE	ND	mg/L	0.001	0.05	ajw	4072 a	200.8	03/05/20	
1050	SILVER	ND	mg/L	0.001	0.05	ajw	4072 a	200.8	03/05/20	
1017	CHLORIDE	6.0	mg/L	0.1	250	ajw	4072 a	300.0	03/04/20	
1055	SULFATE	11.1	mg/L	0.2	250	ajw	4072 a	300.0	03/04/20	
1095	ZINC	ND	mg/L	0.005	5	ajw	4072 a	200.8	03/05/20	
1052	SODIUM	9.6	mg/L	1.0		bj	4072 a	200.7	03/09/20	
1915	HARDNESS as Calcium Carbonate	33.7	mg/L	3.30		bj	4072 a	200.7	03/09/20	
1057	TOTAL DISSOLVED SOLIDS (TDS)	77	mg/L	10	500	ajw	4072 a	SM2540 C	03/06/20	
	POTASSIUM	ND	mg/L	1.0		bj	4072 a	200.7	03/09/20	
	*MAGNESIUM	2.9	mg/L	0.500		bj	4072 a	200.7	03/09/20	
	ALUMINUM	ND	mg/L	0.010	0.2	bj	4072 a	200.7	03/09/20	

NOTES:  
 ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting limit (LRL).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 \* Lab Code - lists the laboratory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

**If you have any questions concerning this report contact us at the above phone number.**



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hillsboro, City of  
150 E. Main Street  
Hillsboro, OR 97123

Reference Number: 20-07437  
Project: ASR Monitoring - Rush IOCs

System Name:  
System ID Number:  
Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
Sample Location: JWC-FW  
County:

Sample Number: 1  
Lab Number: 20\_14540  
Collect Date: 3/2/20 09:03  
Date Received: 3/2/20  
Report Date: 3/10/20  
Sampled By: JA/IR  
Sampler Phone:  
Approved by: ajw,bj,bsp  
Authorized by:

Thanh B Phan  
Lab Manager, Portland

EPA#	ANALYTES	RESULTS	UNITS	LRL	MCL	Analyst	Lab Code*	METHOD	Analyzed	COMMENT
	CALCIUM	8.7	mg/L	0.500		bj	4072 a	200.7	03/09/20	
1030	<b>State Unregulated</b>									
	LEAD	ND	mg/L	0.001	0.015	ajw	4072 a	200.8	03/05/20	
1022	COPPER	ND	mg/L	0.005	1.3	ajw	4072 a	200.8	03/05/20	

NOTES:  
 ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting limit (LRL).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 \* Lab Code - lists the laboratory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

**If you have any questions concerning this report contact us at the above phone number.**