



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



ORELAP WA200008
Idaho WA00097
Page 1 of 2

ORGANICS IN DRINKING WATER

Client Name: Hillsboro, City of
150 E. Main Street
Hillsboro, OR 97123

Reference Number: 15-15801

Project: Semi-Annual Joint Water Comm

System Name: JOINT WATER COMMISSION
System ID Number: 4100379
DWP Source Number: EP-A
Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: JWTP FW Hose - Site ID #1
County: Washington

Field ID: Site ID #1
Lab Number: 15_35201
Date Collected: 8/3/15 08:55
Sampled By: Brian monnin
Sampler Phone:
Report Date: 9/9/15
Approved By: co,kah,pdm,pms,rjk

Authorized By:

Patrick Miller, MS
QA Officer

EPA#	COMPOUNDS	RESULTS	UNITS	LRL	MCL	METHOD	Analyst	Lab	Analyzed	COMMENT
	Synthetic Organic Chemicals									
2105	2,4 - D	ND	mg/L	0.0001		515.4	PMS	WA200008	08/14/15	
2110	2,4,5 - TP (SILVEX)	ND	mg/L	0.0001		515.4	PMS	WA200008	08/14/15	
2035	DI(2-ETHYLHEXYL)-ADIPATE	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2051	ALACHLOR	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2050	ATRAZINE	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2306	BENZO(A)PYRENE	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2010	LINDANE (BHC - GAMMA)	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2046	CARBOFURAN	ND	mg/L	0.001		531.2	HY	WA200008	08/11/15	
2959	CHLORDANE	ND	mg/L	0.0001		508.1	CO	WA200008	08/06/15	
2031	DALAPON	ND	mg/L	0.0005		515.4	PMS	WA200008	08/14/15	
2931	1,2-DIBROMO-3-CHLOROPROPANE	ND	mg/L	0.00002		504.1	KAH	WA200008	08/14/15	
2041	DINOSEB	ND	mg/L	0.0001		515.4	PMS	WA200008	08/14/15	
2032	DIQUAT	ND	mg/L	0.002		549.2	HY	WA200008	08/13/15	
2033	ENDOTHALL	ND	mg/L	0.005		548.1	KAH	WA200008	08/04/15	
2005	ENDRIN	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2946	1,2 - DIBROMOETHANE (EDB)	ND	mg/L	0.00002		504.1	KAH	WA200008	08/14/15	
2034	GLYPHOSATE	ND	mg/L	0.005		547	HY	WA200008	08/18/15	
2067	HEPTACHLOR EPOXIDE "B"	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2065	HEPTACHLOR	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2274	HEXACHLOROBENZENE	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2042	HEXACHLOROCYCLO-PENTADIENE	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2015	METHOXYCHLOR	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2326	PENTACHLOROPHENOL	ND	mg/L	0.0001		515.4	PMS	WA200008	08/14/15	

NOTES:
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; a blank MCL value indicates a level is not currently established.
ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting Limit (LRL).

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

If you have any questions concerning this report contact Gretchen E Schrock at the above phone number.

FORM: SOC_OR

ORGANICS IN DRINKING WATER

EPA#	COMPOUNDS	RESULTS	UNITS	LRL	MCL	METHOD	Analyst	Lab	Analyzed	COMMENT
2039	DI(2-ETHYLHEXYL)-PHTHALATE	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2040	PICLORAM	ND	mg/L	0.0001		515.4	PMS	WA200008	08/14/15	
2383	PCBS (Total Aroclors)	ND	mg/L	0.0002		508.1	CO	WA200008	08/06/15	
2037	SIMAZINE	ND	mg/L	0.0001		525.2	CO	WA200008	08/06/15	
2020	TOXAPHENE	ND	mg/L	0.001		508.1	CO	WA200008	08/06/15	
2036	OXAMYL (VYDATE)	ND	mg/L	0.001		531.2	HY	WA200008	08/11/15	

NOTES:

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; a blank MCL value indicates a level is not currently established.
 ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting Limit (LRL).

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

If you have any questions concerning this report contact Gretchen E Schrock at the above phone number.