



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hillsboro, City of
150 E. Main Street
Hillsboro, OR 97123

Reference Number: 21-00563
Project: ASR Monitoring IOC - Rush

System Name:
System ID Number:
Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
Sample Location: 1 - JWC-FW
County:

Sample Number: 8160
Lab Number: 21_01070
Collect Date: 1/6/21 08:35
Date Received: 1/6/21
Report Date: 1/12/21
Sampled By: IR, AM
Sampler Phone:
Approved by: bj,bsp
Authorized by:

Thanh B Phan
Lab Manager, Portland

EPA#	ANALYTES	RESULTS	UNITS	LRL	MCL	Analyst	Lab Code*	METHOD	Analyzed	COMMENT
1067	Other ALKALINITY	26.5	mg CaCO3/l	10		ase	4072 a	SM2320 B	01/09/21	
	EPA Regulated									
1005	ARSENIC	ND	mg/L	0.001	0.010	bsp	4072 a	200.8	01/07/21	
1010	BARIUM	0.0065	mg/L	0.001	2	bsp	4072 a	200.8	01/07/21	
1015	CADMIUM	ND	mg/L	0.001	0.005	bsp	4072 a	200.8	01/07/21	
1020	CHROMIUM	ND	mg/L	0.001	0.1	bsp	4072 a	200.8	01/07/21	
1035	MERCURY	ND	mg/L	0.0001	0.002	bsp	4072 a	200.8	01/07/21	
1045	SELENIUM	ND	mg/L	0.002	0.05	bsp	4072 a	200.8	01/07/21	
1075	BERYLLIUM	ND	mg/L	0.0003	0.004	bsp	4072 a	200.8	01/07/21	
1036	NICKEL	ND	mg/L	0.001		bsp	4072 a	200.8	01/07/21	
1074	ANTIMONY	ND	mg/L	0.001	0.006	bsp	4072 a	200.8	01/07/21	
1085	THALLIUM	ND	mg/L	0.0001	0.002	bsp	4072 a	200.8	01/07/21	
1024	CYANIDE, AVAILABLE	ND	mg/L	0.005	0.2	bsp	4072 a	OIA-1677-DW	01/08/21	
1025	FLUORIDE	ND	mg/L	0.10	4	srs	4072 a	300.0	01/08/21	
	EPA Regulated (Secondary)									
1028	IRON	ND	mg/L	0.050	0.3	bj	4072 a	200.7	01/08/21	
1032	MANGANESE	ND	mg/L	0.001	0.05	bsp	4072 a	200.8	01/07/21	
1050	SILVER	ND	mg/L	0.001	0.05	bsp	4072 a	200.8	01/07/21	
1017	CHLORIDE	5.12	mg/L	0.1	250	srs	4072 a	300.0	01/08/21	
1095	ZINC	ND	mg/L	0.005	5.00	bsp	4072 a	200.8	01/11/21	
1052	SODIUM	12.0	mg/L	1.0		bj	4072 a	200.7	01/08/21	
1915	HARDNESS as Calcium Carbonate	25.1	mg/L	3.30		bj	4072 a	200.7	01/08/21	
	State Unregulated									
1030	LEAD	ND	mg/L	0.001	0.015	bsp	4072 a	200.8	01/07/21	
1022	COPPER	ND	mg/L	0.005	1.3	bsp	4072 a	200.8	01/07/21	

NOTES:

ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting limit (LRL).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

* Lab Code - lists the laboratory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

If you have any questions concerning this report contact us at the above phone number.