



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



ORELAP WA200008
Idaho WA00097

VOLATILE ORGANIC COMPOUNDS (VOC) REPORT

Client Name: Hillsboro, City of
150 E. Main Street
Hillsboro, OR 97123

Reference Number: 21-12029
Project: Semi-Annual Joint Water Comm

System Name: JOINT WATER COMMISSION
System ID Number: 4100379
DWP Source Number:
Multiple Sources:
Sample Type: A - After treatment
Sample Purpose: C - Compliance
Sample Location: JWTP FW Hose - Site ID #1
County: Washington
Sampled By: JA/RD
Sampler Phone:

Field ID: 10414
Lab Number: 21_23196
Date Collected: 4/7/21 08:40
Date Extracted: 524_210408
Date Analyzed: 04/08/21
Report Date: 5/13/21
Analyst: GSL
Approved By: hy

Authorized By:

Thanh B Phan
Lab Manager, Portland

EPA#	COMPOUNDS	RESULTS	UNITS	LRL	MCL	Method	Lab Code*	COMMENT
	EPA/State Regulated							
2977	1,1 - DICHLOROETHYLENE	ND	mg/L	0.0005	0.007	524.2	4072 a	
2981	1,1,1 - TRICHLOROETHANE	ND	mg/L	0.0005	0.200	524.2	4072 a	
2985	1,1,2 - TRICHLOROETHANE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2980	1,2 - DICHLOROETHANE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2983	1,2 - DICHLOROPROPANE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2378	1,2,4 - TRICHLOROBENZENE	ND	mg/L	0.0005	0.070	524.2	4072 a	
2990	BENZENE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2982	CARBON TETRACHLORIDE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2989	CHLOROBENZENE	ND	mg/L	0.0005	0.100	524.2	4072 a	
2380	CIS - 1,2 - DICHLOROETHYLENE	ND	mg/L	0.0005	0.070	524.2	4072 a	
2992	ETHYLBENZENE	ND	mg/L	0.0005	0.700	524.2	4072 a	
2964	METHYLENE CHLORIDE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2968	O - DICHLOROBENZENE	ND	mg/L	0.0005	0.600	524.2	4072 a	
2969	P - DICHLOROBENZENE	ND	mg/L	0.0005	0.075	524.2	4072 a	
2996	STYRENE	ND	mg/L	0.0005	0.100	524.2	4072 a	
2979	T - 1,2 - DICHLOROETHYLENE	ND	mg/L	0.0005	0.100	524.2	4072 a	
2987	TETRACHLOROETHYLENE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2991	TOLUENE	ND	mg/L	0.0005	1.0	524.2	4072 a	
2955	TOTAL XYLENES	ND	mg/L	0.0005	10.0	524.2	4072 a	
2984	TRICHLOROETHYLENE	ND	mg/L	0.0005	0.005	524.2	4072 a	
2976	VINYL CHLORIDE	ND	mg/L	0.0005	0.002	524.2	4072 a	

NOTES:

If a compound is detected > or = to the Lower Reporting Level, LRL, specified increased monitoring frequencies may occur per PHD.
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA. Blank MCL value indicates a level is not currently established.
ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting Limit (LRL).
* Lab Code - lists the laboratory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.
These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.
If you have any questions concerning this report contact our office at the above phone number.