



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
Corvallis, OR Microbiology/Chemistry (d)  
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hillsboro, City of  
150 E. Main Street  
Hillsboro, OR 97123

Reference Number: 23-04140  
Project: ASR Monitoring IOC - Rush

System Name:  
System ID Number:  
Source Number:  
Multiple Sources:  
Sample Type:  
Sample Purpose: Investigative or Other  
Sample Location: 1 - JWC - FW  
County:

Sample Number: 14932  
Lab Number: 23\_08304  
Collect Date: 2/13/23 08:11  
Date Received: 2/13/23  
Report Date: 2/21/23  
Sampled By: SM  
Sampler Phone:  
Approved by: anp,bj,ljh  
Authorized by:

*Sarah P Miller*

Sarah P Miller  
Lab Manager, Corvallis

EPA#	ANALYTES	RESULTS	UNITS	LRL	MCL	Analyst	Lab Code*	METHOD	Analyzed	COMMENT
1067	<b>Other</b> ALKALINITY	<b>34.1</b>	mg CaCO3/l	1.00		krc	046 a	SM2320 B	02/16/23	
	<b>EPA Regulated</b>									
1005	ARSENIC	<b>ND</b>	mg/L	0.001	<b>0.010</b>	tjb	046 a	200.8	02/16/23	
1010	BARIUM	<b>0.0046</b>	mg/L	0.001	<b>2</b>	tjb	046 a	200.8	02/16/23	
1015	CADMIUM	<b>ND</b>	mg/L	0.001	<b>0.005</b>	tjb	046 a	200.8	02/16/23	
1020	CHROMIUM	<b>ND</b>	mg/L	0.001	<b>0.1</b>	tjb	046 a	200.8	02/16/23	
1035	MERCURY	<b>ND</b>	mg/L	0.0001	<b>0.002</b>	tjb	046 a	200.8	02/16/23	
1045	SELENIUM	<b>ND</b>	mg/L	0.002	<b>0.05</b>	tjb	046 a	200.8	02/16/23	
1075	BERYLLIUM	<b>ND</b>	mg/L	0.0003	<b>0.004</b>	tjb	046 a	200.8	02/16/23	
1036	NICKEL	<b>ND</b>	mg/L	0.001		tjb	046 a	200.8	02/16/23	
1074	ANTIMONY	<b>ND</b>	mg/L	0.001	<b>0.006</b>	tjb	046 a	200.8	02/16/23	
1085	THALLIUM	<b>ND</b>	mg/L	0.0001	<b>0.002</b>	tjb	046 a	200.8	02/16/23	
1024	CYANIDE, AVAILABLE	<b>ND</b>	mg/L	0.005	<b>0.2</b>	tjb	046 a	OIA-1677-DW	02/20/23	
1025	FLUORIDE	<b>ND</b>	mg/L	0.10	<b>4</b>	jwn	046 a	300.0	02/14/23	
	<b>EPA Regulated (Secondary)</b>									
1028	IRON	<b>ND</b>	mg/L	0.050	<b>0.3</b>	bj	046 a	200.7	02/15/23	
1032	MANGANESE	<b>ND</b>	mg/L	0.001	<b>0.05</b>	tjb	046 a	200.8	02/16/23	
1050	SILVER	<b>ND</b>	mg/L	0.001	<b>0.05</b>	tjb	046 a	200.8	02/16/23	
1017	CHLORIDE	<b>5.5</b>	mg/L	0.1	<b>250</b>	jwn	046 a	300.0	02/14/23	
1095	ZINC	<b>ND</b>	mg/L	0.005	<b>5.00</b>	tjb	046 a	200.8	02/16/23	
1052	SODIUM	<b>9.0</b>	mg/L	1.0		bj	046 a	200.7	02/15/23	
1915	HARDNESS as Calcium Carbonate	<b>31.8</b>	mg/L	3.30		bj	046 a	200.7	02/15/23	
	<b>State Unregulated</b>									
1030	LEAD	<b>ND</b>	mg/L	0.001	<b>0.015</b>	tjb	046 a	200.8	02/16/23	
1022	COPPER	<b>ND</b>	mg/L	0.005	<b>1.3</b>	tjb	046 a	200.8	02/16/23	

NOTES:  
 ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting limit (LRL).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 \* Lab Code - lists the laboratory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.

**If you have any questions concerning this report contact us at the above phone number.**