



Burlington, WA *Corporate Laboratory (a)*  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
 Bellingham, WA *Microbiology (b)*  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*  
 9725 SW Commerce Cr Ste A2 - Wilsonville, OR 97070 - 503.682.7802  
 Corvallis, OR *Microbiology/Chemistry (d)*  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
 Bend, OR *Microbiology (e)*  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hillsboro, City of  
 150 E. Main Street  
 Hillsboro, OR 97123

Reference Number: 24-03209  
 Project: ASR Monitoring IOC - Rush

System Name:  
 System ID Number:  
 Source Number:  
 Multiple Sources:  
 Sample Type:  
 Sample Purpose: Investigative or Other  
 Sample Location: 1-JWC-FW  
 County:

Sample Number: 20556  
 Lab Number: 24\_06455  
 Collect Date: 2/7/24 08:50  
 Date Received: 2/7/24  
 Report Date: 2/16/24  
 Sampled By: JR  
 Sampler Phone:  
 Approved by: anp,bj  
 Authorized by:

Thanh B Phan  
 Lab Manager, Portland

EPA#	ANALYTES	RESULTS	UNITS	LRL	MCL	Analyst	Lab Code*	METHOD	Analyzed	COMMENT
1067	<b>Other</b> ALKALINITY	<b>39.6</b>	mg CaCO3/	2.0		ebvp	4072 a	SM2320 B	02/12/24	
	<b>EPA Regulated</b>									
1005	ARSENIC	<b>ND</b>	mg/L	0.001	<b>0.010</b>	bj	4072 a	200.8	02/09/24	
1010	BARIUM	<b>0.0058</b>	mg/L	0.001	<b>2</b>	bj	4072 a	200.8	02/09/24	
1015	CADMIUM	<b>ND</b>	mg/L	0.001	<b>0.005</b>	bj	4072 a	200.8	02/09/24	
1020	CHROMIUM	<b>ND</b>	mg/L	0.001	<b>0.1</b>	bj	4072 a	200.8	02/09/24	
1035	MERCURY	<b>ND</b>	mg/L	0.0002	<b>0.002</b>	tjb	4072 a	245.1	02/14/24	
1045	SELENIUM	<b>ND</b>	mg/L	0.002	<b>0.05</b>	bj	4072 a	200.8	02/09/24	
1075	BERYLLIUM	<b>ND</b>	mg/L	0.0003	<b>0.004</b>	bj	4072 a	200.8	02/09/24	
1036	NICKEL	<b>ND</b>	mg/L	0.001		bj	4072 a	200.8	02/09/24	
1074	ANTIMONY	<b>ND</b>	mg/L	0.001	<b>0.006</b>	bj	4072 a	200.8	02/09/24	
1085	THALLIUM	<b>ND</b>	mg/L	0.0001	<b>0.002</b>	bj	4072 a	200.8	02/09/24	
1024	CYANIDE, AVAILABLE	<b>ND</b>	mg/L	0.005	<b>0.2</b>	tjb	4072 a	OIA-1677-DW	02/12/24	
1025	FLUORIDE	<b>ND</b>	mg/L	0.10	<b>4</b>	bj	4072 a	300.0	02/08/24	
	<b>EPA Regulated (Secondary)</b>									
1028	IRON	<b>ND</b>	mg/L	0.050	<b>0.3</b>	bj	4072 a	200.7	02/13/24	
1032	MANGANESE	<b>ND</b>	mg/L	0.001	<b>0.05</b>	bj	4072 a	200.8	02/09/24	
1050	SILVER	<b>ND</b>	mg/L	0.001	<b>0.05</b>	bj	4072 a	200.8	02/09/24	
1017	CHLORIDE	<b>4.9</b>	mg/L	0.1	<b>250</b>	bj	4072 a	300.0	02/08/24	
1095	ZINC	<b>ND</b>	mg/L	0.005	<b>5.00</b>	bj	4072 a	200.8	02/09/24	
1052	SODIUM	<b>11.0</b>	mg/L	1.0		bj	4072 a	200.7	02/13/24	
1915	HARDNESS as Calcium Carbonate	<b>30.7</b>	mg/L	3.30		bj	4072 a	200.7	02/13/24	
	<b>State Unregulated</b>									
1030	LEAD	<b>ND</b>	mg/L	0.001	<b>0.015</b>	bj	4072 a	200.8	02/09/24	
1022	COPPER	<b>ND</b>	mg/L	0.005	<b>1.3</b>	bj	4072 a	200.8	02/09/24	

**NOTES:**  
 ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting limit (LRL).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 \* Lab Code - lists the laboratory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.

An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.  
 These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header.  
**If you have any questions concerning this report contact us at the above phone number.**  
 FORM: cIOC OR.rpt