

Burlington, WA Corporate Laboratory (a)

Bellingham, WA Microbiology (b)

Portland, OR Microbiology/Chemistry (c)

Corvallis, OR Microbiology/Chemistry (d) 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e) 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Project: Semi-Annual Joint Water Comm

Page 1 of 1

VOLATILE ORGANIC COMPOUNDS (VOC) REPORT

Reference Number: 24-08839 Client Name: Hillsboro, City of

> 150 E. Main Street Hillsboro, OR 97123

> > System Name: JOINT WATER COMMISSION

System ID Number: 4100379 DWP Source Number: EP-A

Multiple Sources:

Sample Type: A - After treatment Sample Purpose: C - Compliance

Sample Location: JWTP Finished Water - Site ID #1

County: Washington

Sampled By: SS, JR

Sampler Phone:

Field ID: 20894

Lab Number: 24_16957 Date Collected: 4/3/24 07:58

Date Extracted: Anatek_240416

Date Analyzed: 04/16/24

Report Date: 5/31/24 Analyst: BKP

Approved By: mcs

Authorized By:

Thanh B Phan Lab Manager, Portland

EPA#	COMPOUNDS	RESULTS	UNITS	LRL	MCL	Method	Lab Code*	COMMENT
	EPA/State Regulated							
2977	1,1 - DICHLOROETHYLENE	ND	mg/L	0.00050	0.007	524.2	ID200001	Analyzed by Anatek
2981	1,1,1 - TRICHLOROETHANE	ND	mg/L	0.00050	0.200	524.2	ID200001	Analyzed by Anatek
2985	1,1,2 - TRICHLOROETHANE	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2980	1,2 - DICHLOROETHANE	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2983	1,2 - DICHLOROPROPANE	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2378	1,2,4 - TRICHLOROBENZENE	ND	mg/L	0.00050	0.070	524.2	ID200001	Analyzed by Anatek
2990	BENZENE	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2982	CARBON TETRACHLORIDE	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2989	CHLOROBENZENE	ND	mg/L	0.00050	0.100	524.2	ID200001	Analyzed by Anatek
2380	CIS - 1,2 - DICHLOROETHYLENE	ND	mg/L	0.00050	0.070	524.2	ID200001	Analyzed by Anatek
2992	ETHYLBENZENE	ND	mg/L	0.00050	0.700	524.2	ID200001	Analyzed by Anatek
2964	METHYLENE CHLORIDE (Dichloromethal	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2968	O - DICHLOROBENZENE	ND	mg/L	0.00050	0.600	524.2	ID200001	Analyzed by Anatek
2969	P - DICHLOROBENZENE	ND	mg/L	0.00050	0.075	524.2	ID200001	Analyzed by Anatek
2996	STYRENE	ND	mg/L	0.00050	0.100	524.2	ID200001	Analyzed by Anatek
2979	T - 1,2 - DICHLOROETHYLENE	ND	mg/L	0.00050	0.100	524.2	ID200001	Analyzed by Anatek
2987	TETRACHLOROETHYLENE	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2991	TOLUENE	ND	mg/L	0.00050	1.0	524.2	ID200001	Analyzed by Anatek
2955	TOTAL XYLENES	ND	mg/L	0.00050	10.0	524.2	ID200001	Analyzed by Anatek
2984	TRICHLOROETHYLENE	ND	mg/L	0.00050	0.005	524.2	ID200001	Analyzed by Anatek
2976	VINYL CHLORIDE	ND	mg/L	0.00050	0.002	524.2	ID200001	Analyzed by Anatek

NOTES:

If a compound is detected > or = to the Lower Reporting Level, LRL, specified increased monitoring frequencies may occur per PHD.

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA. Blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the parameter was not detected above the Lower Reporting Limit (LRL).

Lab Code - lists the laborstory accreditation code plus a letter at the far right to indicate the Edge Analytical lab facility where the analyses was performed.

An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. Estimates of uncertainty are not included in this report. If this information is required please contact us at the phone number listed in the report header