

Client Sample Results

Client: City of Hillsboro, OR
Project/Site: Semi-Annual IOC Rush

Job ID: 170-1927-1

Client Sample ID: 1 - JWC - FW

Lab Sample ID: 170-1927-1

Date Collected: 11/05/25 08:31

Matrix: Drinking Water

Date Received: 11/05/25 13:40

PWSID Number: OR4100379

Method: EPA 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	7.1		0.10	0.015	mg/L			11/07/25 15:43	1
Fluoride	0.037	J	0.10	0.016	mg/L			11/07/25 15:43	1

Method: EPA 200.7 - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Sodium	14	^1+	0.50	0.10	mg/L			11/09/25 23:08	1
Iron	ND		0.050	0.019	mg/L			11/09/25 23:08	1
Manganese	ND		0.0010	0.00097	mg/L			11/09/25 23:08	1

Method: EPA 200.8 - Mercury (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hg	ND		0.00020	0.00010	mg/L			11/11/25 11:55	1

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Antimony	ND		0.0010	0.000096	mg/L			11/10/25 18:09	1
Arsenic	0.00020	J	0.0010	0.000073	mg/L			11/10/25 18:09	1
Barium	0.0040		0.0010	0.000021	mg/L			11/10/25 18:09	1
Beryllium	ND		0.0010	0.000017	mg/L			11/10/25 18:09	1
Cadmium	ND		0.0010	0.000015	mg/L			11/10/25 18:09	1
Chromium	0.00018	J	0.0010	0.000088	mg/L			11/10/25 18:09	1
Copper	0.0015	J	0.0050	0.000050	mg/L			11/10/25 18:09	1
Lead	ND		0.0010	0.000029	mg/L			11/10/25 18:09	1
Nickel	0.00059	J	0.0010	0.000051	mg/L			11/10/25 18:09	1
Silver	0.0012		0.0010	0.00012	mg/L			11/10/25 18:09	1
Selenium	0.00072	J B	0.0010	0.00011	mg/L			11/10/25 18:09	1
Zinc	0.00028	J	0.0050	0.00017	mg/L			11/10/25 18:09	1
Thallium	ND		0.0010	0.000023	mg/L			11/10/25 18:09	1

Method: SM 2340B - Total Hardness (as CaCO3) by calculation

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hardness as calcium carbonate	38		1.0	1.0	mg/L			11/10/25 14:18	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Available (OI CORP OIA-1677)	ND		0.010	0.0050	mg/L			11/07/25 11:04	1
Alkalinity (SM 2320B)	34		1.0	1.0	mg/L			11/11/25 10:27	1

Eurofins Wilsonville