

# Client Sample Results

Client: City of Hillsboro, OR  
 Project/Site: Semi-Annual Joint Water Commission

Job ID: 170-4348-1

**Client Sample ID: JWTP Finished Water - Site ID #1**

**Lab Sample ID: 170-4348-1**

Date Collected: 04/01/26 12:18

Matrix: Drinking Water

Date Received: 04/01/26 14:20

PWSID Number: OR4100379

**Method: EPA-DW 524.2 - Total Trihalomethanes**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Trihalomethanes, Total	0.0155		0.000500	0.0000620	mg/L			04/04/26 16:11	1

**Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Dichlorodifluoromethane	ND		0.0005000	0.0000990	mg/L			04/04/26 16:11	1
				0					
Benzene	ND		0.0005000	0.0001170	mg/L			04/04/26 16:11	1
Carbon tetrachloride	ND		0.0005000	0.0000870	mg/L			04/04/26 16:11	1
				0					
Chlorobenzene	ND		0.0005000	0.0000666	mg/L			04/04/26 16:11	1
				0					
Chloromethane (methyl chloride)	ND		0.0005000	0.0001130	mg/L			04/04/26 16:11	1
Methylene chloride (dichloromethane)	ND		0.0005000	0.0000740	mg/L			04/04/26 16:11	1
				0					
trans-1,2-Dichloroethylene	ND		0.0005000	0.0001050	mg/L			04/04/26 16:11	1
cis-1,2-Dichloroethylene	ND		0.0005000	0.0001380	mg/L			04/04/26 16:11	1
1,2-Dichloroethane	ND		0.0005000	0.0001190	mg/L			04/04/26 16:11	1
Bromomethane	ND		0.0005000	0.0001180	mg/L			04/04/26 16:11	1
Chloroethane	ND		0.0005000	0.0000780	mg/L			04/04/26 16:11	1
				0					
Trichlorofluoromethane (Freon 11)	ND		0.0005000	0.0001830	mg/L			04/04/26 16:11	1
1,1-Dichloroethylene	ND		0.0005000	0.0001100	mg/L			04/04/26 16:11	1
Methyl tert-butyl ether	ND		0.0005000	0.0000740	mg/L			04/04/26 16:11	1
				0					
1,1-Dichloroethane	ND		0.0005000	0.0001330	mg/L			04/04/26 16:11	1
2,2-Dichloropropane	ND		0.0005000	0.0001540	mg/L			04/04/26 16:11	1
Bromochloromethane	ND		0.0005000	0.0001770	mg/L			04/04/26 16:11	1
<b>Chloroform (Trichloromethane)</b>	<b>0.01052</b>		0.0005000	0.0001130	mg/L			04/04/26 16:11	1
1,1,1-Trichloroethane	ND		0.0005000	0.0000790	mg/L			04/04/26 16:11	1
				0					
1,1-Dichloropropene	ND		0.0005000	0.0001130	mg/L			04/04/26 16:11	1
Trichloroethylene (TCE)	ND		0.0005000	0.0000970	mg/L			04/04/26 16:11	1
				0					
1,2-Dichloropropane	ND		0.0005000	0.0000710	mg/L			04/04/26 16:11	1
				0					
Dibromomethane	ND		0.0005000	0.0000990	mg/L			04/04/26 16:11	1
				0					
<b>Bromodichloromethane</b>	<b>0.003915</b>		0.0005000	0.0001170	mg/L			04/04/26 16:11	1
cis-1,3-Dichloropropene	ND		0.0005000	0.0001080	mg/L			04/04/26 16:11	1
trans-1,3-Dichloropropene	ND		0.0005000	0.0001350	mg/L			04/04/26 16:11	1
Toluene	ND		0.0005000	0.0000570	mg/L			04/04/26 16:11	1
				0					
1,1,2-Trichloroethane	ND		0.0005000	0.0000750	mg/L			04/04/26 16:11	1
				0					
1,3-Dichloropropane	ND		0.0005000	0.0001010	mg/L			04/04/26 16:11	1
<b>Chlorodibromomethane</b>	<b>0.001087</b>		0.0005000	0.0000620	mg/L			04/04/26 16:11	1
				0					
Tetrachloroethylene	ND		0.0005000	0.0002760	mg/L			04/04/26 16:11	1
1,1,1,2-Tetrachloroethane	ND		0.0005000	0.0001490	mg/L			04/04/26 16:11	1
Ethylbenzene	ND		0.0005000	0.0001120	mg/L			04/04/26 16:11	1
m,p-Xylenes	ND		0.0005000	0.0002260	mg/L			04/04/26 16:11	1
Styrene	ND		0.0005000	0.0001140	mg/L			04/04/26 16:11	1
Bromoform	ND		0.0005000	0.0001420	mg/L			04/04/26 16:11	1

Euofins Wilsonville

# Client Sample Results

Client: City of Hillsboro, OR  
 Project/Site: Semi-Annual Joint Water Commission

Job ID: 170-4348-1

**Client Sample ID: JWTP Finished Water - Site ID #1**

**Lab Sample ID: 170-4348-1**

Date Collected: 04/01/26 12:18

Matrix: Drinking Water

Date Received: 04/01/26 14:20

PWSID Number: OR4100379

**Method: EPA-DW 524.2 - Volatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
o-Xylene	ND		0.0005000	0.0000720	mg/L			04/04/26 16:11	1
				0					
1,1,2,2-Tetrachloroethane	ND		0.0005000	0.0001010	mg/L			04/04/26 16:11	1
1,2,3-Trichloropropane	ND		0.0005000	0.0000540	mg/L			04/04/26 16:11	1
				0					
Isopropylbenzene	ND		0.0005000	0.0000840	mg/L			04/04/26 16:11	1
				0					
Bromobenzene	ND		0.0005000	0.0000860	mg/L			04/04/26 16:11	1
				0					
N-Propylbenzene	ND		0.0005000	0.0000880	mg/L			04/04/26 16:11	1
				0					
o-Chlorotoluene	ND		0.0005000	0.0000570	mg/L			04/04/26 16:11	1
				0					
p-Chlorotoluene	ND		0.0005000	0.0001220	mg/L			04/04/26 16:11	1
1,3,5-Trimethylbenzene	ND		0.0005000	0.0000660	mg/L			04/04/26 16:11	1
				0					
tert-Butylbenzene	ND		0.0005000	0.0000940	mg/L			04/04/26 16:11	1
				0					
1,2,4-Trimethylbenzene	ND		0.0005000	0.0001120	mg/L			04/04/26 16:11	1
sec-Butylbenzene	ND		0.0005000	0.0001020	mg/L			04/04/26 16:11	1
m-Dichlorobenzene	ND		0.0005000	0.0000840	mg/L			04/04/26 16:11	1
				0					
p-Dichlorobenzene	ND		0.0005000	0.0000920	mg/L			04/04/26 16:11	1
				0					
p-Isopropyltoluene	ND		0.0005000	0.0000990	mg/L			04/04/26 16:11	1
				0					
n-Butylbenzene	ND		0.0005000	0.0000560	mg/L			04/04/26 16:11	1
				0					
o-Dichlorobenzene	ND		0.0005000	0.0000760	mg/L			04/04/26 16:11	1
				0					
1,2,4-Trichlorobenzene	ND		0.0005000	0.0000700	mg/L			04/04/26 16:11	1
				0					
Naphthalene	ND		0.0005000	0.0001460	mg/L			04/04/26 16:11	1
Hexachlorobutadiene	ND		0.0005000	0.0000850	mg/L			04/04/26 16:11	1
				0					
Xylenes, Total	ND		0.0005000	0.0002980	mg/L			04/04/26 16:11	1
1,2,3-Trichlorobenzene	ND		0.0005000	0.0001050	mg/L			04/04/26 16:11	1
Vinyl Chloride (VC)	ND		0.0003000	0.0000770	mg/L			04/04/26 16:11	1
				0					
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
1,2-Dichloroethane-d4 (Surr)	102		70 - 130					04/04/26 16:11	1
4-Bromofluorobenzene (Surr)	99		70 - 130					04/04/26 16:11	1
Toluene-d8 (Surr)	101		70 - 130					04/04/26 16:11	1

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Alachlor	ND		0.000049	0.000024	mg/L		04/07/26 15:27	04/08/26 17:35	1
Atrazine	ND		0.000049	0.000013	mg/L		04/07/26 15:27	04/08/26 17:35	1
Benzo[a]pyrene	ND		0.000020	0.0000039	mg/L		04/07/26 15:27	04/08/26 17:35	1
Aldrin	ND		0.0000098	0.0000098	mg/L		04/07/26 15:27	04/08/26 17:35	1
Butachlor	ND		0.000049	0.000012	mg/L		04/07/26 15:27	04/08/26 17:35	1
Di(2-ethylhexyl)adipate	ND		0.000059	0.000062	mg/L		04/07/26 15:27	04/08/26 17:35	1
Di(2-ethylhexyl)phthalate	ND		0.000059	0.000019	mg/L		04/07/26 15:27	04/08/26 17:35	1

Eurofins Wilsonville

# Client Sample Results

Client: City of Hillsboro, OR  
 Project/Site: Semi-Annual Joint Water Commission

Job ID: 170-4348-1

**Client Sample ID: JWTP Finished Water - Site ID #1**

**Lab Sample ID: 170-4348-1**

Date Collected: 04/01/26 12:18

Matrix: Drinking Water

Date Received: 04/01/26 14:20

PWSID Number: OR4100379

**Method: EPA 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Dieldrin	ND		0.0000098	0.0000069	mg/L		04/07/26 15:27	04/08/26 17:35	1
Endrin	ND		0.0000098	0.0000049	mg/L		04/07/26 15:27	04/08/26 17:35	1
Heptachlor	ND		0.0000098	0.0000049	mg/L		04/07/26 15:27	04/08/26 17:35	1
Heptachlor epoxide	ND		0.0000098	0.0000039	mg/L		04/07/26 15:27	04/08/26 17:35	1
Hexachlorobenzene	ND		0.000049	0.000015	mg/L		04/07/26 15:27	04/08/26 17:35	1
Hexachlorocyclopentadiene	ND		0.000049	0.0000098	mg/L		04/07/26 15:27	04/08/26 17:35	1
gamma-BHC (Lindane)	ND		0.0000098	0.0000029	mg/L		04/07/26 15:27	04/08/26 17:35	1
Methoxychlor	ND		0.000049	0.000043	mg/L		04/07/26 15:27	04/08/26 17:35	1
Metolachlor	ND		0.000049	0.000013	mg/L		04/07/26 15:27	04/08/26 17:35	1
Metribuzin	ND		0.000049	0.000033	mg/L		04/07/26 15:27	04/08/26 17:35	1
Propachlor	ND		0.000049	0.000039	mg/L		04/07/26 15:27	04/08/26 17:35	1
Simazine	ND		0.000049	0.000016	mg/L		04/07/26 15:27	04/08/26 17:35	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
2-Nitro-m-xylene	106		70 - 130				04/07/26 15:27	04/08/26 17:35	1
Triphenylphosphate	119		70 - 130				04/07/26 15:27	04/08/26 17:35	1
Perylene-d12	87		70 - 130				04/07/26 15:27	04/08/26 17:35	1

**Method: EPA 548.1 - Endothall (GC/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Endothall	ND		0.0050	0.0027	mg/L		04/06/26 08:40	04/07/26 12:28	1

**Method: EPA-DW2 504.1 - EDB, DBCP and 1,2,3-TCP (GC)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
1,2,3-Trichloropropane	ND		0.0000201	0.0000040	mg/L		04/07/26 15:15	04/07/26 20:37	1
				1					
1,2-Dibromoethane	ND		0.0000100	0.0000040	mg/L		04/07/26 15:15	04/07/26 20:37	1
				1					
1,2-Dibromo-3-Chloropropane	ND		0.0000100	0.0000020	mg/L		04/07/26 15:15	04/07/26 20:37	1
				1					
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
1,2-Dibromopropane (Surr)	113		60 - 140				04/07/26 15:15	04/07/26 20:37	1

**Method: EPA 505 - Organochlorine Pesticides/PCBs (GC)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chlordane	ND		0.000100	0.0000321	mg/L		04/06/26 13:03	04/06/26 18:40	1
Toxaphene	ND		0.000501	0.0000832	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclor 1016	ND		0.0000702	0.0000221	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclor 1221	ND		0.000100	0.0000792	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclor 1232	ND		0.000100	0.0000852	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclor 1242	ND		0.000100	0.0000722	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclor 1248	ND		0.000100	0.0000231	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclor 1254	ND		0.000100	0.0000351	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclor 1260	ND		0.0000702	0.0000331	mg/L		04/06/26 13:03	04/06/26 18:40	1
Aroclors (Total)	ND		0.000100	0.0000852	mg/L		04/06/26 13:03	04/06/26 18:40	1
Surrogate	%Recovery	Qualifier	Limits				Prepared	Analyzed	Dil Fac
Tetrachloro-m-xylene	90		70 - 130				04/06/26 13:03	04/06/26 18:40	1

Eurofins Wilsonville

# Client Sample Results

Client: City of Hillsboro, OR  
 Project/Site: Semi-Annual Joint Water Commission

Job ID: 170-4348-1

**Client Sample ID: JWTP Finished Water - Site ID #1**

**Lab Sample ID: 170-4348-1**

Date Collected: 04/01/26 12:18

Matrix: Drinking Water

Date Received: 04/01/26 14:20

PWSID Number: OR4100379

### Method: EPA-DW 515.4 - Herbicides (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Silvex (2,4,5-TP)	ND		0.000100	0.0000110	mg/L		04/06/26 08:50	04/07/26 12:30	1
Dinoseb	ND		0.000200	0.0000240	mg/L		04/06/26 08:50	04/07/26 12:30	1
2,4-D	ND		0.000100	0.0000280	mg/L		04/06/26 08:50	04/07/26 12:30	1
Pentachlorophenol	ND		0.0000400	0.0000050	mg/L		04/06/26 08:50	04/07/26 12:30	1
Dalapon	ND		0.00100	0.000122	mg/L		04/06/26 08:50	04/07/26 12:30	1
Picloram	ND		0.000100	0.0000150	mg/L		04/06/26 08:50	04/07/26 12:30	1
Dicamba	ND		0.000100	0.0000170	mg/L		04/06/26 08:50	04/07/26 12:30	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
2,4-Dichlorophenylacetic acid (Surr)	98		70 - 130				04/06/26 08:50	04/07/26 12:30	1

### Method: EPA 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Sulfate	16		0.20	0.10	mg/L			04/04/26 02:56	1

### Method: EPA 531.2 - Carbamate Pesticides (HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Aldicarb	ND		0.00050	0.00016	mg/L		04/04/26 08:02	04/05/26 00:07	1
Aldicarb sulfone	ND		0.00050	0.00017	mg/L		04/04/26 08:02	04/05/26 00:07	1
Aldicarb sulfoxide	ND		0.00050	0.00014	mg/L		04/04/26 08:02	04/05/26 00:07	1
Carbaryl	ND		0.00050	0.00016	mg/L		04/04/26 08:02	04/05/26 00:07	1
Carbofuran	ND		0.00050	0.00010	mg/L		04/04/26 08:02	04/05/26 00:07	1
Methomyl	ND		0.00050	0.00017	mg/L		04/04/26 08:02	04/05/26 00:07	1
Oxamyl (Vydate)	ND		0.00050	0.00017	mg/L		04/04/26 08:02	04/05/26 00:07	1
<b>Surrogate</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
BDMC	116		70 - 130				04/04/26 08:02	04/05/26 00:07	1

### Method: EPA 547 - Glyphosate (DAI HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Glyphosate	ND		0.0060	0.0016	mg/L		04/03/26 14:40	04/04/26 05:53	1

### Method: EPA 549.2 - Diquat and Paraquat (HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Diquat	ND		0.00038	0.00032	mg/L		04/06/26 15:22	04/08/26 19:59	1

### Method: EPA 1613B - Tetra Chlorinated Dioxin (HRGC/HRMS)

Analyte	Result	Qualifier	RL	EDL	Unit	D	Prepared	Analyzed	Dil Fac
2,3,7,8-TCDD	ND		4.8	0.14	pg/L		04/06/26 07:52	04/11/26 02:52	1
<b>Isotope Dilution</b>	<b>%Recovery</b>	<b>Qualifier</b>	<b>Limits</b>				<b>Prepared</b>	<b>Analyzed</b>	<b>Dil Fac</b>
13C-2,3,7,8-TCDD	66		31 - 137				04/06/26 07:52	04/11/26 02:52	1

### Method: EPA 200.7 - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Calcium	9.62		0.100	0.0270	mg/L			04/06/26 17:08	1
Magnesium	3.10		0.100	0.00500	mg/L			04/06/26 17:08	1
Potassium	0.607		0.200	0.00880	mg/L			04/06/26 17:08	1
Silica	18.3		0.0428	0.0150	mg/L			04/06/26 17:08	1

Euofins Wilsonville

# Client Sample Results

Client: City of Hillsboro, OR  
 Project/Site: Semi-Annual Joint Water Commission

Job ID: 170-4348-1

**Client Sample ID: JWTP Finished Water - Site ID #1**

**Lab Sample ID: 170-4348-1**

Date Collected: 04/01/26 12:18

Matrix: Drinking Water

Date Received: 04/01/26 14:20

PWSID Number: OR4100379

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Aluminum	ND		0.0200	0.00230	mg/L			04/06/26 19:44	1
Co	ND		0.00200	0.0000660	mg/L			04/06/26 19:44	1
<b>Strontium</b>	<b>0.0442</b>		0.00200	0.000230	mg/L			04/06/26 19:44	1
Mo	ND		0.00200	0.000420	mg/L			04/06/26 19:44	1

**General Chemistry**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Turbidity (EPA 180.1)	ND		0.10	0.10	NTU			04/02/26 15:42	1
Hardness, Non-Carbonate (SM 2340)	ND		0.100	0.100	mg/L			04/15/26 11:40	1
Ammonia as N (EPA 350.1)	ND		0.0100	0.00850	mg/L			04/06/26 18:07	1
Nitrogen, Kjeldahl (EPA 351.2)	ND		0.200	0.140	mg/L		04/06/26 13:57	04/14/26 15:58	1
Orthophosphate as P (SM 4500 P F)	ND		0.0100	0.00360	mg/L			04/02/26 12:49	1
Total Suspended Solids (USGS I-3765-85)	ND		2.00	2.00	mg/L			04/06/26 11:15	1
<b>Nitrate as N (SM Nitrate by calc)</b>	<b>0.263</b>		0.00500	0.00320	mg/L			04/03/26 10:19	1
Nitrogen, Organic (EPA Nitrogen,Org)	ND		0.200	0.0848	mg/L			04/07/26 15:28	1
Color (SM 2120B)	ND		5.00	5.00	Color Units			04/02/26 16:31	1
Odor (SM 2150B)	ND		1.00	1.00	T.O.N.			04/01/26 17:05	1
<b>Bicarbonate Alkalinity as CaCO3 (SM 2320B)</b>	<b>37.5</b>		1.0	1.0	mg/L			04/07/26 10:47	1
Carbonate Alkalinity as CaCO3 (SM 2320B)	ND		1.0	1.0	mg/L			04/07/26 10:47	1
Hydroxide Alkalinity (SM 2320B)	ND		1.0	1.0	mg/L			04/07/26 10:47	1
Phenolphthalein Alkalinity (SM 2320B)	ND		1.0	1.0	mg/L			04/07/26 10:47	1
<b>Corrosivity (SM 2330B)</b>	<b>-1.36</b>				SU			04/15/26 11:55	1
<b>Specific Conductance (SM 2510B)</b>	<b>123</b>		5.00	5.00	uS/cm			04/03/26 15:26	1
<b>Total Solids (SM 2540B)</b>	<b>99.0</b>		10.0	10.0	mg/L			04/07/26 14:05	1
<b>Total Dissolved Solids (SM 2540C)</b>	<b>87.5</b>		10.0	10.0	mg/L			04/06/26 11:01	1
<b>Total Volatile Solids (SM 2540G)</b>	<b>17.0</b>		5.00	5.00	mg/L			04/13/26 13:20	1
<b>Carbon dioxide, Total (SM 4500 CO2 D)</b>	<b>34.1</b>		0.500	0.500	mg/L			04/15/26 11:48	1
<b>Carbon Dioxide, Free (SM 4500 CO2 D)</b>	<b>1.18</b>		0.500	0.500	mg/L			04/15/26 11:48	1
<b>pH (SM 4500 H+ B)</b>	<b>7.8</b>	HF	0.01	0.01	SU			04/01/26 17:51	1
<b>Temperature (SM 4500 H+ B)</b>	<b>19.7</b>	HF	0.01	0.01	Celsius			04/01/26 17:51	1
Nitrite as N (SM 4500 NO3 F)	ND		0.00500	0.00370	mg/L			04/01/26 16:42	1
<b>Nitrate Nitrite as N (SM 4500 NO3 F)</b>	<b>0.263</b>		0.0100	0.00410	mg/L			04/01/26 16:42	1
<b>Total Organic Carbon (SM 5310B)</b>	<b>1.33</b>		0.150	0.0900	mg/L			04/08/26 21:58	1
Tannin (SM 5550B)	ND		0.100	0.100	mg/L			04/08/26 15:52	1
Phosphorus, Total (SM4500_P_F)	ND		0.0100	0.00290	mg/L		04/10/26 11:08	04/10/26 15:54	1

**General Chemistry - Dissolved**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
<b>Dissolved Organic Carbon (SM 5310B)</b>	<b>1.23</b>		0.500	0.160	mg/L			04/09/26 03:47	1