

Client Sample Results

Client: City of Hillsboro, OR
Project/Site: ASR Monitoring IOC - RUSH

Job ID: 170-6610-1

Client Sample ID: 1 - JWC - FW

Lab Sample ID: 170-6610-1

Date Collected: 08/03/26 08:32

Matrix: Drinking Water

Date Received: 08/03/26 14:30

Method: EPA 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	4.1		0.10	0.027	mg/L			08/07/26 00:16	1
Fluoride	ND		0.10	0.020	mg/L			08/06/26 06:43	1

Method: EPA 200.7 - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Iron	ND		0.0100	0.00860	mg/L			08/07/26 16:34	1
Sodium	7.37		0.100	0.0200	mg/L			08/07/26 16:34	1
Manganese	ND		0.00200	0.00120	mg/L			08/07/26 16:34	1

Method: EPA 200.8 - Mercury (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hg	ND		0.000200	0.0000790	mg/L			08/10/26 21:09	1

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Antimony	ND		0.00100	0.000530	mg/L			08/07/26 13:23	1
Arsenic	ND		0.00100	0.000460	mg/L			08/07/26 13:23	1
Barium	0.00330		0.00200	0.0000990	mg/L			08/07/26 13:23	1
Beryllium	ND		0.000300	0.000120	mg/L			08/07/26 13:23	1
Cadmium	ND		0.000500	0.000180	mg/L			08/07/26 13:23	1
Chromium	ND		0.000900	0.000200	mg/L			08/07/26 13:23	1
Copper	ND		0.00200	0.000360	mg/L			08/07/26 13:23	1
Lead	ND		0.000500	0.0000850	mg/L			08/07/26 13:23	1
Nickel	ND		0.00500	0.00170	mg/L			08/07/26 13:23	1
Selenium	ND		0.00200	0.000430	mg/L			08/07/26 13:23	1
Silver	ND		0.000500	0.000250	mg/L			08/07/26 13:23	1
Thallium	ND		0.000300	0.0000610	mg/L			08/07/26 13:23	1
Zinc	ND		0.00500	0.00120	mg/L			08/07/26 13:23	1

Method: SM 2340B - Total Hardness (as CaCO3) by calculation

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Hardness	25.9		0.660	0.660	mg/L			08/07/26 21:04	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Available (OI CORP OIA-1677)	ND		0.0100	0.00180	mg/L			08/06/26 12:38	1
Alkalinity (SM 2320B)	29.2		1.0	1.0	mg/L			08/05/26 12:51	1

Eurofins Wilsonville