

Client Sample Results

Client: City of Hillsboro, OR
 Project/Site: ASR Monitoring IOC - RUSH

Job ID: 170-5538-1

Client Sample ID: 1 - JWC - FW

Lab Sample ID: 170-5538-1

Date Collected: 06/03/26 08:34

Matrix: Drinking Water

Date Received: 06/03/26 14:15

Method: EPA 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	5.1		0.10	0.027	mg/L			06/09/26 21:50	1
Fluoride	ND		0.10	0.020	mg/L			06/09/26 21:50	1

Method: EPA 200.7 - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Iron	ND		0.0100	0.00860	mg/L			06/05/26 13:06	1
Sodium	8.72		0.100	0.0200	mg/L			06/05/26 13:06	1
Manganese	ND		0.00200	0.00120	mg/L			06/05/26 13:06	1

Method: EPA 200.8 - Mercury (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hg	ND		0.000200	0.0000790	mg/L			06/05/26 14:00	1

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Antimony	ND		0.00100	0.000530	mg/L			06/05/26 12:56	1
Arsenic	ND		0.00100	0.000460	mg/L			06/05/26 12:56	1
Barium	0.00408		0.00200	0.0000990	mg/L			06/05/26 12:56	1
Beryllium	ND		0.000300	0.000120	mg/L			06/05/26 12:56	1
Cadmium	ND		0.000500	0.000180	mg/L			06/05/26 12:56	1
Chromium	ND		0.000900	0.000200	mg/L			06/05/26 12:56	1
Copper	ND		0.00200	0.000360	mg/L			06/05/26 12:56	1
Lead	ND		0.000500	0.0000850	mg/L			06/05/26 12:56	1
Nickel	ND		0.00500	0.00170	mg/L			06/05/26 12:56	1
Selenium	ND		0.00200	0.000430	mg/L			06/05/26 12:56	1
Silver	ND		0.000500	0.000250	mg/L			06/05/26 12:56	1
Thallium	ND		0.000300	0.0000610	mg/L			06/05/26 12:56	1
Zinc	ND		0.00500	0.00120	mg/L			06/05/26 12:56	1

Method: SM 2340B - Total Hardness (as CaCO3) by calculation

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Hardness	29.5		0.660	0.660	mg/L			06/05/26 17:07	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Available (OI CORP OIA-1677)	ND		0.0100	0.00180	mg/L			06/12/26 12:24	1
Alkalinity (SM 2320B)	34.3		1.0	1.0	mg/L			06/09/26 13:43	1