

# Client Sample Results

Client: City of Hillsboro, OR  
 Project/Site: ASR Monitoring IOC - RUSH

Job ID: 170-3880-1

**Client Sample ID: 1 - JWC - FW**

**Lab Sample ID: 170-3880-1**

Date Collected: 03/04/26 08:05

Matrix: Drinking Water

Date Received: 03/04/26 14:15

**Method: EPA 300.0 - Anions, Ion Chromatography**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	5.6		0.10	0.015	mg/L			03/05/26 18:35	1
Fluoride	ND		0.10	0.016	mg/L			03/05/26 18:35	1

**Method: EPA 200.7 - Metals (ICP)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Iron	ND		0.0100	0.00860	mg/L			03/24/26 17:35	1
Sodium	10.2		0.100	0.0200	mg/L			03/24/26 17:35	1
Manganese	ND		0.00200	0.00120	mg/L			03/24/26 17:35	1

**Method: EPA 200.8 - Mercury (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hg	ND		0.000200	0.0000790	mg/L			03/10/26 20:23	1

**Method: EPA 200.8 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Antimony	ND		0.00100	0.000530	mg/L			03/10/26 10:46	1
Arsenic	ND		0.00100	0.000460	mg/L			03/10/26 10:46	1
Barium	0.00589	B **	0.00200	0.0000990	mg/L			03/10/26 10:46	1
Beryllium	ND		0.000300	0.000120	mg/L			03/10/26 10:46	1
Cadmium	ND		0.000500	0.000180	mg/L			03/10/26 10:46	1
Chromium	ND		0.000900	0.000200	mg/L			03/10/26 10:46	1
Copper	ND		0.00200	0.000360	mg/L			03/10/26 10:46	1
Lead	ND		0.000500	0.0000850	mg/L			03/10/26 10:46	1
Nickel	ND		0.00500	0.00170	mg/L			03/10/26 10:46	1
Selenium	ND		0.00200	0.000430	mg/L			03/10/26 10:46	1
Silver	ND		0.000500	0.000250	mg/L			03/10/26 10:46	1
Thallium	ND		0.000300	0.0000610	mg/L			03/10/26 10:46	1
Zinc	ND		0.00500	0.00120	mg/L			03/10/26 10:46	1

**Method: SM 2340B - Total Hardness (as CaCO3) by calculation**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Hardness	32.5		0.660	0.660	mg/L			03/25/26 16:29	1

**General Chemistry**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Available (OI CORP OIA-1677)	ND		0.0100	0.00500	mg/L			03/12/26 14:23	1
Alkalinity (SM 2320B)	34.3		1.0	1.0	mg/L			03/09/26 11:54	1