

Client Sample Results

Client: City of Hillsboro, OR
 Project/Site: ASR Monitoring IOC - RUSH

Job ID: 170-4978-1

Client Sample ID: 1 - JWC - FW

Lab Sample ID: 170-4978-1

Date Collected: 05/06/26 09:00

Matrix: Drinking Water

Date Received: 05/06/26 14:06

Method: EPA 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Chloride	6.1		0.10	0.027	mg/L			05/13/26 17:19	1
Fluoride	ND		0.10	0.020	mg/L			05/13/26 17:19	1

Method: EPA 200.7 - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Iron	ND		0.0100	0.00860	mg/L			05/11/26 13:54	1
Sodium	10.4		0.100	0.0200	mg/L			05/11/26 13:54	1
Manganese	ND		0.00200	0.00120	mg/L			05/11/26 13:54	1

Method: EPA 200.8 - Mercury (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Hg	ND		0.000200	0.0000790	mg/L			05/11/26 19:16	1

Method: EPA 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Antimony	ND		0.00100	0.000530	mg/L			05/11/26 15:49	1
Arsenic	ND		0.00100	0.000460	mg/L			05/11/26 15:49	1
Barium	0.00538		0.00200	0.0000990	mg/L			05/11/26 15:49	1
Beryllium	ND		0.000300	0.000120	mg/L			05/11/26 15:49	1
Cadmium	ND		0.000500	0.000180	mg/L			05/11/26 15:49	1
Chromium	ND		0.000900	0.000200	mg/L			05/11/26 15:49	1
Copper	0.00221		0.00200	0.000360	mg/L			05/11/26 15:49	1
Lead	ND		0.000500	0.0000850	mg/L			05/11/26 15:49	1
Nickel	ND		0.00500	0.00170	mg/L			05/11/26 15:49	1
Selenium	ND		0.00200	0.000430	mg/L			05/11/26 15:49	1
Silver	ND		0.000500	0.000250	mg/L			05/11/26 15:49	1
Thallium	ND		0.000300	0.0000610	mg/L			05/11/26 15:49	1
Zinc	ND		0.00500	0.00120	mg/L			05/11/26 15:49	1

Method: SM 2340B - Total Hardness (as CaCO3) by calculation

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Total Hardness	37.3		0.660	0.660	mg/L			05/12/26 12:18	1

General Chemistry

Analyte	Result	Qualifier	RL	MDL	Unit	D	Prepared	Analyzed	Dil Fac
Cyanide, Available (OI CORP OIA-1677)	ND		0.0100	0.00180	mg/L			05/11/26 12:32	1
Alkalinity (SM 2320B)	42.0		1.0	1.0	mg/L			05/08/26 13:31	1